

Tender Inviting Authority: Staff officer (E&M), Magadh - Sanghmitra Area, CCL						
Name of the Work / Contract No:	Work of "Erection and installation of 6.6 kv O/H Line from 33 KV/6.6KV substation 1E at Ara to 1.) Proposed one number 250 KVA 6.6 kv/440 V Distribution Transformer to be installed near kundli WB-7(Route length approx. 500 metre) and 2.(A) Proposed one number 500KVA 6.6KV/440 V unitized substation to be installed near GM Office Ara (Route length 3 KM approx.) and 2.(B) Erection of 6.6 KV overhead line by tapping from check –post:9 which is proposed to be drawn from 33/6.6 kv Substation 1E at Ara to proposed one number 250 KVA 440 V distribution transformer to be installed near Chamatu Road Weighbridge No-13(route length approx. 2KM) of Magadh OCP, under M-S Area to make it complete in all respects on a turnkey basis."			NIT No: G.M.(M-S)/S.O.(E&M)/e-NIT/25-26/53; Dated:- 01.12.2025.		
Category of Services (To Be Selected by Department)		Category of Bidder (To Be Selected by Bidder)				
ITC Not Available	Works Contract	Bidder's Status (Mandatory)	Total GST(in Rs.)	GST to be Paid By Bidder (in Rs.)	GST to be Paid By CIL/Subsidiary (in Rs.)	
Name of the Bidder/ Bidding Firm / Company :		Select	0.00	0.00	0.00	
<p align="center">PRICE SCHEDULE</p> <p>(This BOQ template must not be modified/replaced by the bidder and the same should be uploaded after filling the relevant columns, else the bidder is liable to be rejected for this tender. Bidders are allowed to enter the Bidder Name and Values only)</p>						
NUMBER #	TEXT #	NUMBER #	TEXT #	NUMBER #	NUMBER #	TEXT #
Sl. No.	Item Description	Quantity	Units	BASIC RATE In Figures To be entered by the Bidder in Rs. P	TOTAL AMOUNT Without Taxes in Rs. P	TOTAL AMOUNT In Words
1	2	3	4	6	7	8
1	Supply of 13 metre Steel Tubular pole	16	Nos.		0.00	INR Zero Only
2	Supply of 16 metre Steel tubular pole	4	Nos.		0.00	INR Zero Only
3	Erection of steel tubular or rail pole strut in cement concrete 1:3:6 (1 cement: 3 coarse sand 6 graded stone aggregate 40 mm nominal size) foundation including excavation and refilling and secured with holding clamps, bolts,nuts, etc.as required for 13 metre steel tubular pole.	16	Nos.		0.00	INR Zero Only
4	Erection of metallic pole of length upto 16 mtr in cement concrete 1:3:6 (1 cement: 3 coarse sand: 6 graded stone aggregate 40 mm nominal size) foundation including excavation and refilling etc. as required.	4	Nos.		0.00	INR Zero Only
5	Supplying of two lengths of channel iron 75 mm X 40 mm X 6 mm (7.14 kg per metre) double pole crass arm for three wire 11KV over head line conductors complete with through bolts and nuts for clamping to the poles, 50 mm X 6 mm M.S. flats welded on one side to the channel iron and with bolts and nuts on the other side for tying the cross arms together, including drilling holes for insulator pins/fittings, bolts, nuts and washers etc (as per drawing) and painting with primer and finish paint as required.	12	Set		0.00	INR Zero Only
6	Erection of double pole 3 wire cross arm for 11KV/22KV/33 KV over head lines as required.	12	Set		0.00	INR Zero Only
7	Supplying of channel iron 75 mm X 40 mm X 6 mm (7.14 kg per metre) pole top bracket/cross arm for single 11 KV over head line conductor complete with 50 mm X 6mm flat iron clamp, bolts, nuts and washers including drilling holes for insulator pins, bolts and nuts etc and painting with primer and finish paint as required	5	Set		0.00	INR Zero Only
8	Erection of pole top cross arm on steel tubular/ rail/PCC pole for 11 KV	5	Set		0.00	INR Zero Only

9	Supplying of channel iron 75 mm X 40 mm X 6 mm (7.14 kg per metre) V shape cross arm for two 11 KV over head line conductors complete with 50 mm X 6 mm M.S. flat iron clamps, bolts and nuts including drilling holes for insulator pins, bolts, nuts and washers etc (as per drawing) and painting with primer and finish paint as required	5	Set		0.00	INR Zero Only
10	Erection of pole V shape two wire, angle iron/channel iron, cross arm on steel tubular/rail/ PCC pole for 11KV	5	Set		0.00	INR Zero Only
11	Supplying and erection of a set of cross bracing FRL Some work for 11 KV over head line double pole structure having four members fabricated out of 50 mm x 50 mm x 6 mm angle iron to form a rectangle of minimum size 1400 mm width x 2500mm height complete with 50mm x 6mm M.S. flat iron clamps bolts and nuts including drilling holes for insulator pins.bolts and nuts etc (as per drawing)and painting with primer and finish paint as required	9	Set		0.00	INR Zero Only
12	Supplying and erection of 11 KV disc insulator for 11 KV over head lines with galvanised insulator fitting ball and socket type and complete with galvanised strain clamps, bolts, nuts, washers etc. as required	33	Set		0.00	INR Zero Only
13	Supplying and erection of 11 KV pin insulator complete with large steel head G.I.	36	Set		0.00	INR Zero Only
14	Supplying and erection of galvanised stay set for 11 KV over head lines complete with 19/20 mm dia X 1.8 metres long stay rod, anchor plate of size 45 cm x 45 cm x 7.5 mm thick, thimble, stay clamps, turn buckle (20 mm x 600 mm), 7/4.00 mm dia G.I. stay wire and 11 KV strain insulator etc in cement concrete 1:3:6 (1 cement: 3 coarse sand. 6 graded stone aggregate 40 mm nominal size) foundation including excavation and refilling etc. as required	8	Set		0.00	INR Zero Only
15	Supply of 125 sq mm AAA DOG Conductor (1500+1500 X 10 % Wastage including binding etc)=1650 MTR)	1650	Mtr		0.00	INR Zero Only
16	Erection of ACSR conductor of 7/3.35 mm to 7/4.00 diameter and above including binding etc. as required. (1650 X 0.342) 564.3 KG	564.3	kg		0.00	INR Zero Only
17	Loading unloading of Tubular pole and conductor from store point to erection site	1	Job		0.00	INR Zero Only
18	Painting with aluminium paint of approved brand and manufacture to give an even shade Two or more coats on new work.	20	Each		0.00	INR Zero Only
19	Earthing with GI earth plate 600 mm X 600 mm X 6 mm thick including accessories, and providing masonry enclosure with cover plate having locking arrangement and watering pipe of 2.7 metre long etc.with charcoal/coke and salt as required.	7	Nos.		0.00	INR Zero Only
20	Providing and fixing 25 mm X 5 mm GI strip on surface or in recess for connections etc as required	35	Mtr		0.00	INR Zero Only
21	Supplying and erection of three piece non linear resistor type lightning arrester suitable for 3 wire, 11kv overhead lines with rated voltage 9 KV(rms) with a nominal discharge current rating of 5 KA and complete with galvanised clamping arrangement GI bolts,nuts, washers etc. as required	4	Set		0.00	INR Zero Only
22	Supplying of channel iron 75mmX40mmX6mm [7.14kgpermetre) cross arm for 2 wire over head line complete with clamps,bolts,nuts and washer etc including drilling of holes for insulator pins etc (as per drawing)and painting with primer and finished paint as required. (For fixing of earth continuity wire in top of over head line)	13	Set		0.00	INR Zero Only
23	Erection of angle. Tran/channel iron cross arm on /RCC/PCC/steel tubular or Rail pole for 2 wire system.	13	Set		0.00	INR Zero Only

24	Supply of 55 sq mm AAA Conductor for continuous earthing wire (500 mtr 10% wastage- 550 mtr	550	Mtr		0.00	INR Zero Only
25	Erection of 55 sq mm rabbit conductor for loop earthing (550mtr x 148kg/mtr)	81.4	kg		0.00	INR Zero Only
26	Supply of SWG G.I wire	69	kg		0.00	INR Zero Only
27	Erection of G.I wire no-6/8 SWG including binding etc as required for cage cradle and crosslacing GI Wire (50 mtr span $((50*2)+(1.5*10))*0.148\text{kg/mtr})=17.02\text{kg}$ X 4 span = 68.08KG In round figure 69 kg	69	kg		0.00	INR Zero Only
28	Supply of 3 Core 6.6 kv 185 sq mm (UE) Aluminium conductor, Stranded Compacted Circular Aluminium Conductor, Conductor Screen with Extruded Semi Conducting Compound, XLPE Insulated, Insulation Screening with Extruded Semi Conducting Compound in Combination with Copper Tape, Cores Laid Up, Innersheath of PVC, Galvanised Steel Flat Strip Armoured, & Overall PVC Sheathed Cable Conforming to IS 7098 (Part-2) 2011 with upto Date Amendments.	150	Mtr		0.00	INR Zero Only
29	Laying of one number additional PVC insulated and PVC sheathed/XLPE power cable of 11 KV grade of following size direct in ground in the same trench in one tier horizontal formation including excavation, sand cushioning, protective covering and refilling the trench etc as required Above 120 sq. mm and upto 400 sq. mm	150	Mtr		0.00	INR Zero Only
30	Supplying and making outdoor cable and termination with heat shrinkable jointing kit complete with all accessories including lugs suitable for following size of 3 core, XLPE aluminium conductor cable of 11 kv grade as required: upto 240 sq mm	6	Set		0.00	INR Zero Only
31	Supplying and fixing of light class G.I. pipe of 100 mm dia. (nominal) 3 metres length along the pole for protection of under ground cable as required.	5	Set		0.00	INR Zero Only
32	Provision of 11 kv 400 Amps (porcelain) Vertical type with operating items GOAB Switch with dropout fuse including it's all fixing arrangements	2	Nos.		0.00	INR Zero Only
33	Providing and fixing H.T. danger notice plate of 250 mm X 200 mm, made of mild steel, at least 2 mm thick, and vitreous enameled white on both sides, and with inscription in single red colour on front side as required.	20	Nos.		0.00	INR Zero Only
34	Supply of 13 metre Steel Tubular pole	72	Nos.		0.00	INR Zero Only
35	Supply of 16 metre Steel tubular pole	6	Nos.		0.00	INR Zero Only
36	Erection of steel tubular or rail pole strut in cement concrete 1:3:6 (1 cement: 3 coarse sand 6 graded stone aggregate 40 mm nominal size) foundation including excavation and refilling and secured with holding clamps, bolts, nuts, etc. as required for 13 metre steel tubular pole.	72	Nos.		0.00	INR Zero Only
37	Erection of metallic pole of length upto 16 mtr in cement concrete 1:3:6 (1 cement: 3 coarse sand: 6 graded stone aggregate 40 mm nominal size) foundation including excavation and refilling etc. as required.	6	Nos.		0.00	INR Zero Only
38	Supplying of two lengths of channel iron 75 mm X 40 mm X 6 mm (7.14 kg per metre) double pole cross arm for three wire 11KV over head line conductors complete with through bolts and nuts for clamping to the poles, 50 mm X 6 mm M.S. flats welded on one side to the channel iron and with bolts and nuts on the other side for tying the cross arms together, including drilling holes for insulator pins/fittings, bolts, nuts and washers etc (as per drawing) and painting with primer and finish paint as required.	18	Set		0.00	INR Zero Only
39	Erection of double pole 3 wire cross arm for 11KV/22KV/33 KV over head lines as required.	18	Set		0.00	INR Zero Only

40	Supplying of channel iron 75 mm X 40 mm X 6 mm (7.14 kg per metre) pole top bracket/cross arm for single 11 KV over head line conductor complete with 50 mm X 6mm flat iron clamp, bolts, nuts and washers including drilling holes for insulator pins, bolts and nuts etc and painting with primer and finish paint as required	45	Set		0.00	INR Zero Only
41	Erection of pole top cross arm on steel tubular/rail/PCC pole for 11 KV	45	Set		0.00	INR Zero Only
42	Supplying of channel iron 75 mm X 40 mm X 6 mm (7.14 kg per metre) V shape cross arm for two 11 KV over head line conductors complete with 50 mm X 6 mm M.S. flat iron clamps, bolts and nuts including drilling holes for insulator pins, bolts, nuts and washers etc (as per drawing) and painting with primer and finish paint as required	45	Set		0.00	INR Zero Only
43	Erection of pole V shape two wire, angle iron/channel iron, cross arm on steel tubular/rail/ PCC pole for 11KV	45	Set		0.00	INR Zero Only
44	Supplying and erection of a set of cross bracing FRL. Some work for 11 KV over head line dottle pole structure having four members fabricated out of 50 mm x 50 mm x 6 mm angle iron to form a rectangle of minimum size 1400 mm width x 2500mm height complete with 50mm x 6mm M.S. flat iron clamps bolts and nuts including drilling holes for insulator pins. bolts and nuts etc (as per drawing) and painting with primer and finish paint as required	18	Set		0.00	INR Zero Only
45	Supplying and erection of 11 KV disc insulator for 11 KV over head lines with galvanised insulator fitting ball and socket type and complete with galvanised strain clamps, bolts, nuts, washers etc. as required	96	Set		0.00	INR Zero Only
46	Supplying and erection of 11 KV pin insulator complete with large steel head G.I.	183	Set		0.00	INR Zero Only
47	Supplying and erection of galvanised stay set for 11 KV over head lines complete with 19/20 mm dia X 1.8 metres long stay rod, anchor plate of size 45 cm x 45 cm x 7.5 mm thick, thimble, stay clamps, turn buckle (20 mm x 600 mm), 7/4.00 mm dia G.I. stay wire and 11 KV strain insulator etc in cement concrete 1:3:6 (1 cement: 3 coarse sand. 6 graded stone aggregate 40 mm nominal size) foundation including excavation and refilling etc. as required	30	Set		0.00	INR Zero Only
48	Supply of 125 sq mm AAA DOG Conductor (1500+1500 X 10 % Wastage including binding etc)=1650 MTR)	9900	Mtr		0.00	INR Zero Only
49	Erection of ACSR conductor of 7/3.35 mm to 7/4.00 diameter and above including binding etc. as required. (1650 X 0.342) 564.3 KG	3385.85	kg		0.00	INR Zero Only
50	Loading unloading of Tubular pole and conductor from store point to erection site	1	Job		0.00	INR Zero Only
51	Painting with aluminium paint of approved brand and manufacture to give an even shade Two or more coats on new work.	78	Each		0.00	INR Zero Only
52	Earthing with GI earth plate 600 mm X 600 mm X 6 mm thick including accessories, and providing masonry enclosure with cover plate having locking arrangement and watering pipe of 2.7 metre long etc. with charcoal/coke and salt as required.	16	Nos.		0.00	INR Zero Only
53	Providing and fixing 25 mm X 5 mm GI strip on surface or in recess for connections etc as required	80	Mtr		0.00	INR Zero Only
54	Supplying and erection of three piece non linear resistor type lightning arrestor suitable for 3 wire, 11kv overhead lines with rated voltage 9 KV(rms) with a nominal discharge current rating of 5 KA and complete with galvanised clamping arrangement GI bolts, nuts, washers etc. as required	2	Set		0.00	INR Zero Only

55	Supplying of channel iron 75mmX40mmX6mm [7.14kgpermetre) cross arm for 2 wire over head line complete with clamps,bolts,nuts and washer etc including drilling of holes for insulator pins etc (as per drawing)and painting with primer and finished paint as required. (For fixing of earth continuity wire in top of over head line)	60	Set		0.00	INR Zero Only
56	Erection of angle. Tran/channel iron cross arm on /RCC/PCC/steel tubular or Rail pole for 2 wire system.	60	Set		0.00	INR Zero Only
57	Supply of 55 sq mm AAA Conductor for continuous earthing wire (3300 mtr + 10% wastage = 3300 mtr	3300	Mtr		0.00	INR Zero Only
58	Erection of 55 sq mm rabbit conductor for loop earthing (3300 mtr x .148kg/mtr)	488.4	kg		0.00	INR Zero Only
59	Supply of SWG G.I wire	69	kg		0.00	INR Zero Only
60	Erection of G.I wire no-6/8 SWG including binding etc as required for cage cradle and crosslacing GI Wire (50 mtr span ((50*2)+(1.5*10))*0.148kg/mtr)=17.02kg X 4 span = 68.08KG In round figure 69 kg	69	kg		0.00	INR Zero Only
61	Supply of 3 Core 6.6 kv 120 sq mm (UE) Aluminium conductor, Stranded Compactdt Circular Aluminium Conductor, Conductor Screen with Extruded Semi Conducting Compound, XLPE Insulated, Insulation Screening with Extruded Semi Conducting Compound in Combination with Copper Tape, Cores Laid Up, Innersheath of PVC, Galvanised Steel Flat Strip Armoured, & Overall PVC Sheathed Cable Conforming to IS 7098 (Part-2) 2011 with upto Date Amendments.	50	Mtr		0.00	INR Zero Only
62	Laying of one number additional PVC insulated and PVC sheathed/XLPE power cable of 11 KV grade of following size direct in ground in the same trench in one tier horizontal formation including excavation, sand cushioning, protective covering and refilling the trench etc as required Above 120 sq. mm	50	Mtr		0.00	INR Zero Only
63	Supplying and making outdoor cable and termination with heat shrinkable jointing kit complete with all accessories including lugs suitable for following size of 3 core, XLPE aluminium conductor cable of 11 kv grade as required: upto 120 sq mm	2	Set		0.00	INR Zero Only
64	Supplying and fixing of light class G.I. pipe of 100 mm dia. (nominal) 3 metres length along the pole for protection of under ground cable as required.	2	Set		0.00	INR Zero Only
65	Provision of 11 kv 400 Amps (porcelain) Vertical type with operating items GOAB Switch with dropout fuse including it's all fixing arrangements	2	Nos.		0.00	INR Zero Only
66	Providing and fixing H.T. danger notice plate of 250 mm X 200 mm,made of mild steel, at least 2 mm thick, and vitreous enameled white on both sides, and with inscription in single red colour on front side as required.	78	Nos.		0.00	INR Zero Only
67	Supply of 13 metre Steel Tubular pole	47	Nos.		0.00	INR Zero Only
68	Supply of 16 metre Steel tubular pole	6	Nos.		0.00	INR Zero Only
69	Erection of steel tubular or rail pole strut in cement concrete 1:3:6 (1 cement: 3 coarse sand 6 graded stone aggregate 40 mm nominal size) foundation including excavation and refilling and secured with holding clamps, bolts,nuts, etc.as required for 13 metre steel tubular pole.	47	Nos.		0.00	INR Zero Only
70	Erection of metallic pole of length upto 16 mtr in cement concrete 1:3:6 (1 cement: 3 coarse sand: 6 graded stone aggregate 40 mm nominal size) foundation including excavation and refilling etc. as required.	6	Nos.		0.00	INR Zero Only

71	Supplying of two lengths of channel iron 75 mm X 40 mm X 6 mm (7.14 kg per metre) double pole cross arm for three wire 11KV over head line conductors complete with through bolts and nuts for clamping to the poles, 50 mm X 6 mm M.S. flats welded on one side to the channel iron and with bolts and nuts on the other side for tying the cross arms together, including drilling holes for insulator pins/fittings, bolts, nuts and washers etc (as per drawing) and painting with primer and finish paint as required.	13	Set		0.00	INR Zero Only
72	Erection of double pole 3 wire cross arm for 11KV/22KV/33 KV over head lines as required.	13	Set		0.00	INR Zero Only
73	Supplying of channel iron 75 mm X 40 mm X 6 mm (7.14 kg per metre) pole top bracket/cross arm for single 11 KV over head line conductor complete with 50 mm X 6mm flat iron clamp, bolts, nuts and washers including drilling holes for insulator pins, bolts and nuts etc and painting with primer and finish paint as required	30	Set		0.00	INR Zero Only
74	Erection of pole top cross arm on steel tubular/rail/PCC pole for 11 KV	30	Set		0.00	INR Zero Only
75	Supplying of channel iron 75 mm X 40 mm X 6 mm (7.14 kg per metre) V shape cross arm for two 11 KV over head line conductors complete with 50 mm X 6 mm M.S. flat iron clamps, bolts and nuts including drilling holes for insulator pins, bolts, nuts and washers etc (as per drawing) and painting with primer and finish paint as required	30	Set		0.00	INR Zero Only
76	Erection of pole V shape two wire, angle iron/channel iron, cross arm on steel tubular/rail/ PCC pole for 11KV	30	Set		0.00	INR Zero Only
77	Supplying and erection of a set of cross bracing FRLSome work for 11 KV over head line doultile pole structure having four members fabricated out of 50 mm x 50 mm x 6 mm angle iron to form a rectangle of minimum size 1400 mm width x 2500mm heigh complete with 50mm x 6mm M.S. flat iron clamen bolts and nuts including dritting holes for insulator pins.bolts and nuts etc (as per drawing)and painting with primer and finish paint at required	13	Set		0.00	INR Zero Only
78	Supplying and erection of 11 KV disc insulator for 11 KV over head lines with galvanised insulator fitting ball and socket type and complete with galvanised strain clamps, bolts, nuts, washers etc. as required	66	Set		0.00	INR Zero Only
79	Supplying and erection of 11 KV pin insulator complete with large steel head G.I.	123	Set		0.00	INR Zero Only
80	Supplying and erection of galvanised stay set for 11 KV over head lines complete with 19/20 mm dia X 1.8 metres long stay rod, anchor plate of size 45 cm x 45 cm x 7.5 mm thick, thimble, stay clamps, turn buckle (20 mm x 600 mm), 7/4.00 mm dia G.I. stay wire and 11 KV strain insulator etc in cement concrete 1:3:6 (1 cement: 3 coarse sand. 6 graded stone aggregate 40 mm nominal size) foundation including excavation and refilling etc. as required	20	Set		0.00	INR Zero Only
81	Supply of 125 sq mm AAA DOG Conductor (6000+6000 X 10 % Wastage including binding etc)=6600 MTR)	6600	Mtr		0.00	INR Zero Only
82	Erection of ACSR conductor of 7/3.35 mm to 7/4.00 diameter and above including binding etc. as required. (6600 X 0.342) = 2257.20 KG	2257	kg		0.00	INR Zero Only
83	Loading unloding of Tubular pole and conductor from store point to erection site	1	Job		0.00	INR Zero Only
84	Painting with aluminium paint of approved brand and manufacture to give an even shade Two or more coats on new work.	53	Each		0.00	INR Zero Only

85	Earthing with GI earth plate 600 mm X 600 mm X 6 mm thick including accessories, and providing masonry enclosure with cover plate having locking arrangement and watering pipe of 2.7 metre long etc.with charcoal/coke and salt as required.	11	Nos.		0.00	INR Zero Only
86	Providing and fixing 25 mm X 5 mm GI.strip on surface or in recess for connections etc as required	65	Mtr		0.00	INR Zero Only
87	Supplying and erection of three piece non linear resistor type lightning arrestor suitable for 3 wire, 11kv overhead lines with rated voltage 9 KV(rms) with a nominal discharge current rating of 5 KA and complete with galvanised clamping arrangement GI bolts,nuts, washers etc. as required	2	Set		0.00	INR Zero Only
88	Supplying of channel iron 75mmX40mmX6mm [7.14kgpermetre) cross arm for 2 wire over head line complete with clamps,bolts.nuts and washer etc including drilling of holes for insulator pins etc (as per drawing)and painting with primer and finished paint as required. (For fixing of earth continuity wire in top of over head line)	40	Set		0.00	INR Zero Only
89	Erection of angle. Tran/channel iron cross arm on /RCC/PCC/steel tubular or Rail pole for 2 wire system.	40	Set		0.00	INR Zero Only
90	Supply of 55 sq mm AAA Conductor for continuous earthing wire (2000 mtr + 10% wastage = 2200 mtr	2200	Mtr		0.00	INR Zero Only
91	Erection of 55 sq mm rabbit conductor for loop earthing (2200mtr x .148kg/mtr)	325.6	kg		0.00	INR Zero Only
92	Supply of SWG G.I wire	69	kg		0.00	INR Zero Only
93	Erection of G.I wire no-6/8 SWG including binding etc as required for cage cradle and crosslacing GI Wire (50 mtr span ((50*2)+(1.5*10))*0.148kg/mtr))=17.02kg X 4 span = 68.08KG In round figure 69 kg	69	kg		0.00	INR Zero Only
94	Supply of 3 Core 6.6 kv 185 sq mm (UE) Aluminium conductor, Stranded Compactdt Circular Aluminium Conductor, Conductor Screen with Extruded Semi Conducting Compound, XLPE Insulated, Insulation Screening with Extruded Semi Conducting Compound in Combination with Copper Tape, Cores Laid Up, Innersheath of PVC, Galvanised Steel Flat Strip Armoured, & Overall PVC Sheathed Cable Conforming to IS 7098 (Part-2) 2011 with upto Date Amendments.	50	Mtr		0.00	INR Zero Only
95	Laying of one number additional PVC insulated and PVC sheathed/XLPE power cable of 11 KV grade of following size direct in ground in the same trench in one tier horizontal formation including excavation, sand cushioning, protective covering and refilling the trench etc as required Above 120 sq. mm and upto 120 sq. mm	50	Mtr		0.00	INR Zero Only
96	Supplying and making outdoor cable and termination with heat shrinkable jointing kit complete with all accessories including lugs suitable for following size of 3 core, XLPE aluminium conductor cable of 11 kv grade as required: upto 120 sq mm	2	Set		0.00	INR Zero Only
97	Supplying and fixing of light class G.I. pipe of 100 mm dia. (nominal) 3 metres length along the pole for protection of under ground cable as required.	2	Set		0.00	INR Zero Only
98	Provision of 11 kv 400 Amps (porcelain) Vertical type with operating items GOAB Switch with dropout fuse including it's all fixing arrangements	2	Nos.		0.00	INR Zero Only
99	Providing and fixing H.T. danger notice plate of 250 mm X 200 mm,made of mild steel, at least 2 mm thick, and vitreous enameled white on both sides, and with inscription in single red colour on front side as required.	53	Nos.		0.00	INR Zero Only
100	Total impact of GST for the purpose of CTC	1.000	Job	0.00	0.00	INR Zero Only
Total in Figures					0.00	INR Zero Only
Quoted Rate in Words					INR Zero Only	