

ITC Not Available	Works Contract	Bidder's Status (Mandatory)	Rate of GST (in %)	Total GST(in Rs.)	GST to be Paid By Bidder (in Rs.)	GST to be Paid By CIL/Subsidiary (in Rs.)
Name of the Bidder/ Bidding Firm / Company :		Select	18	0.00	0.00	0.00

PRICE SCHEDULE

(This BOQ template must not be modified/replaced by the bidder and the same should be uploaded after filling the relevant columns, else the bidder is liable to be rejected for this tender. Bidders are allowed to enter the Bidder Name and Values only)

NUMBER #	TEXT #	NUMBER #	TEXT #	NUMBER	NUMBER #	NUMBER #	TEXT #
Sl. No.	Item Description	Quantity	Units	Estimated Rate in Rs. P	BASIC RATE In Figures To be entered by the Bidder in Rs. P	TOTAL AMOUNT Without Taxes in Rs. P	TOTAL AMOUNT In Words
1	2	3	4	5	6	7	8
1.01	"(A) Installation of 750KVA, 3.3KV/440V, Transformer at new mines colony for using as colony of GVP Phase-II OCP. Erection of metallic pole of following length in cement concrete 1:3:6 (1 cement : 3 coarses sand : 6 graded stone aggregate 40 mm nominal size) foundation including excavation and refilling etc. as required (Above 10 mtrs. Upto 12 mtrs.)	2.00	Nos.			0.00	INR Zero Only
1.02	Supplying and erection of galvanised stay set for 11KV overhead lines complete with 19/20 mm dia X 1.8 metres long stay rod, anchor plate of size 45cm X 45cm X 7.5mm thick, thimble, stay clamps, turn buckle (20mm X 600mm), 7/4.00 mm dia G.I stay wire and 11KV strain insulator etc in cement concrete 1:3:6 (1 cement : 3 coarses and : 6 graded stone aggregate 40mm nominal size) foundation including excavation and refilling etc. as required.	2.00	Nos.			0.00	INR Zero Only
1.03	GOAB switch 11KV grade, 800A	1.00	Set			0.00	INR Zero Only
1.04	Commissioning of 11KV GOAB	1.00	No.			0.00	INR Zero Only
1.05	Erection of ACSR conductor of 7/3.35 mm to 7/4.00 mm diameter including binding etc as required (1 Span x 30 mtrs. X 3 wire = 90 mtrs. X 0.394 Kgs = 35.46 Kg) (For jumphering = 1.5 mtrs. X 3 wire x 01 no. = 4.5 mtrs. X 0.394 Kgs = 1.77 Kg)	37.23	Kg			0.00	INR Zero Only
1.06	Supplying and erection of a set of cross bracing FRL Same work for 11 KV over head line double pole structure having four members fabricated out of 50 mm X 50 mm X 6 mm angle iron to form a rectangle of minimum size 1400 mm width X 2500 mm height, complete with 50 mm X 6mm M.S. flat iron clamps, bolts and nuts including drilling holes for insulator pins, bolts and nuts etc (us per drawing) and painting with primer and finish paint as required.	1.00	Set			0.00	INR Zero Only

1.07	Supplying of two lengths of channel iron 75 mm X 40 mm X 6 mm (7.14 kg per metre) double pole cross arm for three wire 11KV over head line conductors complete with through bolts and nuts for clamping to the poles, 50 mm X 6 mm M.S. flats welded on one side to the channel iron and with bolts and nuts on the other side for tying the cross arms together, including drilling holes for insulator pins/ fittings, bolts, nuts and washers etc (as per drawing) and painting with primer and finish paint as required.	3.00	Nos.			0.00	INR Zero Only
1.08	Erection of double pole 3 wire cross arm for 11K V/22KV/33 KV over head lines as required.	3.00	Nos.			0.00	INR Zero Only
1.09	Supplying & erection of 11 KV disc insulator for 11 KV over head lines with galvanized insulator fittings, ball socket type and complete with galvanized strain clamps, bolts, nuts washers etc as required.	6.00	Nos.			0.00	INR Zero Only
1.10	Supply and erection of 11 KV pin insulator complete with large steel head G.I in nuts washers etc as required.	9.00	Nos.			0.00	INR Zero Only
1.11	Earth work in excavation by mechanical means (Hydraulic excavator)/ manual means over areas (exceeding 30 cm in depth, 1.5 m inwidth as well as 10 sqm on plan) including disposal of excavatedearth, lead upto 50 m and lift upto 1.5 m, disposed earth to be levelledand neatly dressed. Ordinary rock For Transformer Foundation - 1.5 mtr X 1.5 mtrX 1 mtr 2.25 CuM	2.25	Cu.M			0.00	INR Zero Only
1.12	Brick work with common burnt clay modular bricks of class designation 7.5 in foundation and plinth in:Cement mortar 1:4 (1 cement: 4 coarse sand) For Transformer 0.24 X 1.25 Mtrs X 1.25 Mtrs X 4 Side	1.50	Cu.M			0.00	INR Zero Only
1.13	Supplying and filling in plinth sand under floors, including watering, ramming, consolidating and dressing complete Total yard 1.5 For Transformer 1 Mtr x 1 Mtr x 1.25 Mtr = 1.25 Cu.M	1.25	Cu.M			0.00	INR Zero Only
1.14	Providing and laying in position cement concrete of specified grade excluding the cost of centering and shuttering - All work up to plinth level:1:3:6 (1 Cement: 3 coarse sand: 6 graded stone aggregate 20 mm nominal size) For Transformer 0.24 MtrX 1.25 X 1.25 Mtr 0.375 CuM	0.375	Cu.M			0.00	INR Zero Only
1.15	Making of chemical earthpit of resistance at different locations as per direction of Engineer Incharge or his representative. (1). Safe earthing electrode having two custom made G.I. tubes (Galvanized 80 micros, minimum one inside the other of length 3 mtr (outer dia 80mm) filled with conductor rich crystalline mixture (CCM) (2.) Back fill compound (bag of 25 kg each).	3.00	Nos.			0.00	INR Zero Only

1.16	Earth work in excavation by mechanical means (Hydraulic 5.04 excavator)/ manual means over areas (exceeding 30 cm in depth, 1.5 m inwidth as well as 10 sqm on plan) including disposal of excavatedearth, lead upto 50 m and lift upto 1.5 in, disposed carth to be levelledand neatly dressed. (3 x .75 x .75- 1.68 x 3 Nos. 5.04 Cu.M	5.04	Cu.M			0.00	INR Zero Only
1.17	Providing and fixing 25 mm X 5 mm G.I. strip on surface 30 or in recess for connections etc. as required.	30.00	Mtrs.			0.00	INR Zero Only
1.18	Supplying & fixing of 800 Amps MCCB	1.00	Nos.			0.00	INR Zero Only
1.19	Providing & fixing of copper wire - 8 SWG for Making of Fuse system	6.00	Nos.			0.00	INR Zero Only
1.20	Supplying and erection of three piece nonlinear resistor type lightning arrestor suitable for 3 wire, 11KV overhead lines with rated valtage 9KV (rms) with a nominal discharge current rating of 5 KA and complete with galvanised clamping arrangement, G.I. bolts, nuts, washers etc. as required.	1.00	Set			0.00	INR Zero Only
1.21	(B) Installation of 50KVA, 3.3KV /440V, Transformer at Sawang main sub-station at SWG-GVP Ph-II OCP. Erection of metallic pole of following length in cement concrete1:3:6(1cement :3coarsesand :6graded stone aggregate 40 mm nominal size) foundation including excavation and refilling etc. as required (Above 10 mtrs. Upto 12 mtrs.)	2.00	Nos.			0.00	INR Zero Only
1.22	Supplying and erection of galvanised stay set for 11KV overhead lines complete with 19/20 mm dia X 1.8 metres long stay rod, anchor plate of size 45cm X 45cm X 7.5mm thick, thimble, stay clamps, turn buckle (20mm X 600mm), 7/4.00 mm dia G.I stay wire and 11KV strain insulator etc in cement concrete 1:3:6 (1cement :3coarses and :6graded stone aggregate 40mm nominal size) foundation including excavation and refilling etc. as required.	2.00	Nos.			0.00	INR Zero Only
1.23	GOAB switch 11KV grade, 800A	1.00	Set			0.00	INR Zero Only
1.24	Commissioning of 11KV GOAB	1.00	No.			0.00	INR Zero Only
1.25	Erection of ACSR conductor of 7/3.35 mm to 7/4.00 mm diameter including binding etc as required (1 Span x 30 mtrs. X 3 wire = 90 mtrs. X 0.394 Kgs = 35.46 Kg) (For jumphering = 1.5 mtrs. X 3 wire x 01 no. = 4.5 mtrs. X 0.394 Kgs = 1.77 Kg)	37.23	Kg			0.00	INR Zero Only
1.26	Supplying and erection of a set of cross bracing FRLSame work for 11 KV over head line double pole structure having four members fabricated out of 50 mm X 50 mm X 6 mm angle iron to form a rectangle of minimum size 1400 mm width X 2500 mm height, complete with 50 mm X 6mm M.S. flat iron clamps, bolts and nuts including drilling holes for insulator pins, bolts and nuts ete (us per drawing) and painting with primer and finish paint as required.	1.00	Set			0.00	INR Zero Only

1.27	Supplying of two lengths of channel iron 75 mm X 40 mm X 6 mm (7.14 kg per metre) double pole cross arm for three wire 11KV over head line conductors complete with through bolts and nuts for clamping to the poles, 50 mm X 6 mm M.S. flats welded on one side to the channel iron and with bolts and nuts on the other side for tying the cross arms together, including drilling holes for insulator pins/ fittings, bolts, nuts and washers etc (as per drawing) and painting with primer and finish paint as required.	3.00	Nos.			0.00	INR Zero Only
1.28	Erection of double pole 3 wire cross arm for 11K V/22KV/33 KV over head lines as required.	3.00	Nos.			0.00	INR Zero Only
1.29	Supplying & erection of 11 KV disc insulator for 11 KV over head lines with galvanized insulator fittings, ball socket type and complete with galvanized strain clamps, bolts, nuts washers etc as required.	6.00	Nos.			0.00	INR Zero Only
1.30	Supply and erection of 11 KV pin insulator complete with large steel head G.I in nuts washers etc as required.	9.00	Nos.			0.00	INR Zero Only
1.31	Earth work in excavation by mechanical means (Hydraulic excavator)/ manual means over areas (exceeding 30 cm in depth, 1.5 m inwidth as well as 10 sqm on plan) including disposal of excavatedearth, lead upto 50 m and lift upto 1.5 m, disposed earth to be levelledand neatly dressed. Ordinary rock For Transformer Foundation - 1.5 mtr X 1.5 mtrX 1 mtr 2.25 CuM	2.25	Cu.M			0.00	INR Zero Only
1.32	Brick work with common burnt clay modular bricks of class designation 7.5 in foundation and plinth in:Cement mortar 1:4 (1 cement: 4 coarse sand) For Transformer 0.24 X 1.25 Mtrs X 1.25 Mtrs X 4 Side	1.50	Cu.M			0.00	INR Zero Only
1.33	Supplying and filling in plinth sand under floors, including watering, ramming, consolidating and dressing complete Total yard 1.5 For Transformer 1 Mtr x 1 Mtr x 1.25 Mtr = 1.25 Cu.M	1.25	Cu.M			0.00	INR Zero Only
1.34	Providing and laying in position cement concrete of specified grade excluding the cost of centering and shuttering - All work up to plinth level:1:3:6 (1 Cement: 3 coarse sand: 6 graded stone aggregate 20 mm nominal size) For Transformer 0.24 MtrX 1.25 X 1.25 Mtr 0.375 CuM	0.375	Cu.M			0.00	INR Zero Only
1.35	Making of chemical earthpit of resistance at different locations as per direction of Engineer Incharge or his representative. (1). Safe earthing electrode having two custom made G.I. tubes (Galvanized 80 micros, minimum one inside the other of length 3 mtr (outer dia 80mm) filled with conductor rich crystalline mixture (CCM) (2.) Back fill compound (bag of 25 kg each).	3.00	Nos.			0.00	INR Zero Only

1.36	Earth work in excavation by mechanical means (Hydraulic 5.04 excavator)/ manual means over areas (exceeding 30 cm in depth, 1.5 m inwidth as well as 10 sqm on plan) including disposal of excavatedearth, lead upto 50 m and lift upto 1.5 in, disposed carth to be levelledand neatly dressed. (3 x .75 x .75- 1.68 x 3 Nos. 5.04 Cu.M	5.04	Cu.M			0.00	INR Zero Only
1.37	Providing and fixing 25 mm X 5 mm G.I. strip on surface 30 or in recess for connections etc. as required.	30.00	Mtrs.			0.00	INR Zero Only
1.38	Supplying & fixing of 400 Amps MCCB	1.00	No.			0.00	INR Zero Only
1.39	Providing & fixing of copper wire - 8 SWG for Making of Fuse system	6.00	Nos.			0.00	INR Zero Only
1.40	Supplying and erection of three piece nonlinear resistor type lightning arrester suitable for 3 wire, 11KV overhead lines with rated valtage 9KV (rms) with a nominal discharge current rating of 5 KA and complete with galvanised clamping arrangement, G.I. bolts, nuts, washers etc. as required.	1.00	Set			0.00	INR Zero Only
2	Total impact of GST for the purpose of CTC	1	No.		0.00	0.00	INR Zero Only
Total in Figures						0.00	INR Zero Only
Quoted Rate in Words		INR Zero Only					